



NOTES:

1. PROVIDE A "DRESSER-TYPE" COUPLING ON METER ASSEMBLY INSTALLATIONS IN VAULTS TO ALLOW FOR EASY REMOVAL OF FLANGED COMPONENTS.
2. METERING ASSEMBLY TO BE PROPERLY INSTALLED AND ADEQUATELY SUPPORTED TO ALLOW FOR EASY MAINTENANCE, REPAIR AND REPLACEMENT.

WATER METER/PRV CONFIGURATION – LESS THAN 2"
N.T.S.



WATER METER
PRV ENTRANCE
LESS THAN 2"